

Memo No:- 150

Date:- 09/02/2026

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KTL/05169/2/2026	Sample Details	Date & Time
Sample Classification:	Private		
Sender:	BALWAN SINGH	Collected By	SATISH KUMAR,9355154321
Location :-	, PM SHRI GSSS BALBEHRA	Collection Date	06/02/2026 at 10:23
Latitude :-	76.387930	Received at lab	06/02/2026 at 10:27
Longitude :-	30.025534	Tested at Lab	09/02/2026

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	9	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in KAITHAL lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**NOT CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**NOT POTABLE**"



SUBHASH CHANDER,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,KAITHAL
email:-chemist.kaithal@phedharyana.gov.in

-----End of Report-----.